


CODES

< WHERE & WHAT >

WHERE FIRE PROTECTION IS REQUIRED




WHAT KIND OF FIRE PROTECTION IS REQUIRED




STANDARDS

< HOW >


HOW FIRE PROTECTION IS INSTALLED




NFPA 10 provides requirements to ensure that **portable fire extinguishers** will work as intended to provide a first line of defense against fires of limited size.



NFPA 14 provides requirements for the installation of **standpipes and hose systems** to ensure that systems will work as intended to deliver adequate and reliable water supplies in a fire emergency.



NFPA 17 standard includes the minimum requirements to ensure that **dry chemical fire extinguishing systems** will function as intended throughout their life to protect life and property from fire.



NFPA 17A applies to the design, installation, operation, testing, and maintenance of **wet chemical extinguishing systems**. Includes minimum requirements for restaurant and institutional hoods, plenums, ducts, and associated cooking appliances.